

# Dryer Venting Checklist

- Dryer exhaust should be vented according to manufacturers' instructions.
- Dryer exhaust systems must be separate from all other ventilation systems.
- Dryer exhaust must not be placed within or near insulation.
- A vertical riser must be included for cleaning out the system.
- All dryer ventilation ducts must lead outdoors.
- Makeup air must be provided if more than 0.09 m<sup>3</sup>/s of air is extracted by the dryer in one room.
- All dryer ducts must be made from metal with a smooth surface on the interior.
- Dryer ducts may be no longer than 25 ft.